


Customer [REDACTED] Date Oct 17/90  
 Serial No. CEDAR RAPIDS NIFE  
 Remarks AYLMER, PQ

**FEED END**

*Old Cedar Rapids*

*Hitting Structure Badly*

**CENTER**

**LEFT**  **RIGHT**

**DISCHARGE END**

*03 17/90 on file*

*1/2" stroke*

*780 RPM*

**BIG Problem Here....**

**Erratic Stroke check on feed end right, indicates unit is NON free floating & an Interference FIT with the Structure**

**CAUSE: Poor Housekeeping - built up Material**

**51" x 20' OF120C - 4367 Serial Number Oct 17/90**